

# DRINKING WATER NOTICE

## **Sky Manor Restaurant Failed to Conduct a Detailed Level 2 Assessment to Identify Sanitary Defects after Testing Positive for Total Coliform.**

Our water system detected coliform bacteria on 06/08/2022 in the distribution system which was the second time during the past 12 months. When this occurs, we are required to conduct a detailed Level 2 Assessment to identify and correct any sanitary defects (problems) that are found. Sky Manor Restaurant failed to conduct the required detailed assessment by 07/29/2022 as required under the Revised Total Coliform Rule.

As our customers, you have a right to know what happened and what we are doing to correct the situation.

### **What does this mean?**

This is not an emergency. If it had been an emergency, you would have been notified within 24 hours.

We failed to conduct the required Level 2 Assessment.

*\*Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. \**

Failure to conduct a detailed assessment to identify and correct sanitary defects has the potential to cause distribution system contamination. Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches. We are committed to correcting the deficiency to eliminate the threat of contamination.

### **What should I do?**

- You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.

- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from their health care providers about drinking this water. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at (800) 426-4791.

- If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

### **What is being done?**

- We completed a detailed assessment on 10/07/2022

For more information, please contact Rosella Caloiero, manager of Sky Manor Restaurant, at 908-996-3442 or write to 48 Sky Manor Rd, Pittstown, NJ 08867.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being posted by Sky Manor Restaurant.  
PWSID: NJ1001302  
Distributed: 11/16/2022